



**City of California City  
Building Department  
21000 Hacienda Blvd  
California City, CA 93505**

**Checklist for Expedited Solar Systems Permitting**

**GENERAL REQUIREMENTS**

- |  |   |   |
|--|---|---|
| A. System size is 10 kW AC CEC rating or less  | Y | N |
| B. The solar array is roof-mounted on one- or two-family dwelling or accessory structure | Y | N |
| C. The solar panel/module arrays will not exceed the maximum legal building height       | Y | N |
| D. Solar system is utility interactive and without battery storage                       | Y | N |
| E. Permit application is completed and attached  | Y | N |
| F. The plans have the size of the Main Breaker on the existing Meter Panel               | Y | N |
| G. The plans state the type of existing grounding system (ufer, rod, etc.)               | Y | N |
| H. The plans state the size of the existing grounding electrode conductor                | Y | N |
| I. The plans state whether the service wires are overhead feed or an underground feed    | Y | N |
| J. The plans state that all work will meet 2016 California Electrical Codes              | Y | N |

**ELECTRICAL REQUIREMENTS**

- |  |   |   |
|--|---|---|
| A. No more than four photovoltaic module strings are connected to each Maximum Power Point Tracking (MPPT) input where source circuit fusing is included in the inverter | Y | N |
| 1) No more than two strings per MPPT input where source circuit fusing is not included   | Y | N |
| 2) Fuses (if needed) are rated to the series fuse rating of the PV module  | Y | N |
| 3) No more than one noninverter-integrated DC combiner is utilized per inverter  | Y | N |
| B. For central inverter systems: No more than two inverters are utilized   | Y | N |
| C. The PV system is interconnected to a single-phase AC service panel of nominal 120/220 Vac with a bus bar rating of 225 A or less                                      | Y | N |
| D. The PV system is connected to the load side of the utility distribution equipment   | Y | N |
| E. A Solar PV Standard Plan and supporting documentation is completed and attached   | Y | N |

**STRUCTURAL REQUIREMENTS**

- |   |   |   |
|---|---|---|
| A. A completed Structural Criteria and supporting documentation is attached, with wind speed calculated at 100 mph minimum. | Y | N |
|---|---|---|

**FIRE SAFETY REQUIREMENTS**

- |  |   |   |
|--|---|---|
| A. Clear access pathways provided  | Y | N |
| B. Fire classification solar system is provided  | Y | N |
| C. All required markings and labels are provided   | Y | N |
| D. A diagram of the roof layout of all panels, modules, clear access pathways and approximate locations of electrical disconnecting means and roof access points is completed and attached | Y | N |

**Notes:**

1. These criteria are intended for expedited solar permitting process.
2. If any items are checked NO, revise design to fit within Eligibility Checklist, otherwise permit application may go through standard process.

**Joe Barragan  
Building Official for California City  
Office (760) 373-7162  
Fax (760) 373-7532  
Email address: [jbarragan@californiacity-ca.gov](mailto:jbarragan@californiacity-ca.gov)**